

ORIGINAL


FORM NO. 2829002

(WELL # 1)
PEERLESS PUMP

INSTALLED APPROX 1974

SURFACE DISCHARGE

104 MAIN STREET
P.O. BOX 4
PACIFIC GROVE, CALIF. 93920
PHONE: 719-256-2000



MOTOR: _____ MFR. V.H.S. TYPE
 H.P. _____ CY. _____ VOLTS _____
 RPM. _____ PH. _____ FRAME _____

BASE TO C. OF DISCHARGE _____
 DISCHARGE COMPANION FLANGE FOR: _____
 DISCHARGE HEAD _____
 O.D. TOP COL. FLANGE _____

PUMP RATING
 G.P.M. 140
 FT. FIELD HD. 300'

AIR LINE SET. APPROX 45'

* PUMP PULLED DEC. 2015
 REPLACED 3 RUBBER BEARINGS, NEW ALTITUDE GAUGE & AIRLINE -

S.O. NO. _____
 SOLD TO: _____
 ORDER NO. _____
 USER: VILLAGE OF SINCLAIRVILLE
 ITEM NO. _____
 PUMP IDENTIFICATION: _____

THIS CERTIFIED PRINT
 FOR APPROVAL
 BY _____ DATE _____
 FOR CONSTRUCTION
 BY _____ DATE _____

fmc HYDRODYNAMICS DIVISION
PEERLESS PUMP
 Los Angeles 31, Calif • Indianapolis 8 Ind

DRN BY F.E. CHK'D BY _____ DATE DEC 28, 15